

Applicant : SAS Power Industries FZE
(Subsidiary of Galfar Al Misnad Engg. & Contg., WLL)
P.O. Box 54505
RAS Al Khaimah
United Arab Emirates

Application Date : 13 October 2015

Order Number : 2184038.00-INC

Product : Low-voltage switchgear and controlgear assembly

Trade name : SAS-GALFAR

Type/Model : Representative IK Test Enclosure for SAS Galfar Switchgear Systems

Arnhem, 26 April 2017

Manufacturer/ Production sites: SAS Power Industries FZE
(Subsidiary of Galfar Al Misnad Engg. & Contg., WLL)
P.O. Box 54505
RAS Al Khaimah
United Arab Emirates

Subject : Mechanical impact test


Requirements : IEC 61439-2:2011
Clause 10.2.6

Conclusion : The product complies with the specified requirements

Tested by : R. Verhagen



Checked by : F.S. Strikwerda



RVer

17-0245

© DEKRA Certification B.V. All rights reserved

Products may only be provided with a quality mark or put on the market as approved if DEKRA Certification B.V. has explicitly granted the right to carry a quality mark.

DEKRA Certification B.V. and/or its subsidiaries are not liable for any direct or indirect, incidental or consequential loss originating through or because of the use of the information or data from this document or due to the impossibility of using that information or data.

The contents of this report may not be made available to a third party other than as an entity provided with the aforementioned designations with respect to copyrights and liability.