

# UL TYPE EXAMINATION CERTIFICATE

|   |  |
|---|--|
| <b>Certificate No.</b>  | UL TEC-01050   |
| <b>Page</b>   | 1/1  |
| <b>Date of Issue</b>  | 2021-05-30   |
| <b>Issued to</b>  | SAS POWER INDUSTRIES FZE<br>(GALFAR AL MISNAD ENGINEERING & CONTRACTING WLL)<br>PLOT NO-8, RAK ECONOMIC ZONE<br>PO BOX 54505 RAS AL KHAIMAH UNITED ARAB EMIRATES   |
| <b>Manufacturer</b>   | SAS POWER INDUSTRIES FZE<br>(GALFAR AL MISNAD ENGINEERING & CONTRACTING WLL)<br>PLOT NO-8, RAK ECONOMIC ZONE<br>PO BOX 54505 RAS AL KHAIMAH UNITED ARAB EMIRATES   |
| <b>Manufacturing site/location</b>                                    | SAS POWER INDUSTRIES FZE<br>(GALFAR AL MISNAD ENGINEERING & CONTRACTING WLL)<br>PLOT NO-8, RAK ECONOMIC ZONE<br>PO BOX 54505 RAS AL KHAIMAH UNITED ARAB EMIRATES   |
| <b>Product Sample Description</b>                                     | 1250A Low Voltage Power Switchgear and Controlgear assembly, extendable comprising of one incomer MCCB, seven outgoing MCCB, one outgoing star delta starter and one outgoing DOL starter with three-phase and neutral busbar system and a protective busbar. The Assembly is suitable for indoor use with metallic enclosure.   |
| <b>Designation</b>  | 1250A DEFT PLUS SWITCH BOARD MDB/SMDB/MCC  |
| <b>Ratings</b>  | Rated operational voltage ( $U_g$ ): 415V<br>Rated insulation voltage ( $U_i$ ) : 1000V for 1Q1, 2Q1, 2Q3, 3Q1, 3Q2 & 3Q6<br>: 800V for 3Q3 & 3Q5<br>: 690V for 2Q2 & 3Q4<br>Rated impulse withstand voltage ( $U_{imp}$ ): 8kV for all component except 2Q2 & 3Q4<br>: 6kV for 2Q2 & 3Q4<br>Rated current of the ASSEMBLY ( $I_{nA}$ ) : 1250A<br>Rated frequency ( $f_n$ ): 50Hz, Ambient Temperature: 50°C<br>IP rating: IP 43 (Form 4b), Rated diversity factor (RDF): 1<br>Mechanical impact: IK10<br>Rated short time withstand current ( $I_{cw}$ ): 36kA for 3sec & 50kA for 1sec<br>Refer Type Examination summary for other details (4789863221.1.1-C-S) |
| <b>Product Sample Tested and found in compliance with Standard(s)</b> | IEC 61439-2:2020, IEC 61439-1:2020   |
| <b>Test Report Nos.</b>   | 4789863221.1.1-C issued on 2021-05-02  |
| <b>Additional information</b>   | N/A  |

**Certification Manager**  
Jan-Erik Storgaard

**Certification Body**

This is to certify that the sample(s) of the Product described herein has been investigated and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/ Manufacturer are solely and fully responsible for any declaration of ongoing conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A, 2750  
Ballerup, Denmark, Tel. +45 44 85 65 65,  
[info.dk@ul.com](mailto:info.dk@ul.com)  
[www.ul.com](http://www.ul.com)**

